

**Plans have been reviewed under the 2006 IBC, 2006 UMC,UPC, the 2005 NEC and
2006 SOUTHERN NEVADA POOL CODE.**

TIMER BOXES ARE NOT PERMITTED AS A DISCONNECT FOR MOTORS UNLESS APPROVED BY THE AUTHORITY HAVING JURISDICTION.	PLANS HAVE NOT BEEN REVIEWED FOR COMPLIANCE TO FEDERALLY MANDATED PROVISIONS FOR PERSONS WITH DISABILITIES.
THIS PERMIT IS FOR THE POOL ONLY. SEPARATE PERMITS ARE REQUIRED FOR FENCES, PATIO COVERS, BARBECUES	PROTECTIVE BARRIERS MUST COMPLY WITH SECTION 700 OF THE 2006 SOUTHERN NEVADA POOL CODE.
POOL STEPS SHALL HAVE A MAXIMUM RISE OF 12" (10" FOR COMMERCIAL), A MINIMUM RUN OF 12" AND A MAXIMUM VARIATION BETWEEN ALL STEPS OF 1".	ALL POOL PANELS MUST HAVE A MINIMUM #10 WIRE FEEDER AND 30 AMP BREAKER AND AN INSULATED GROUND WIRE TO THE EXISTING PANEL.
ALL GAS LINES UNDER SLABS, AND/OR FOUNDATIONS, SHALL BE SLEEVED PER THE 2006 UPC SECTION 1211.4	
DECKS SHALL BE AT LEAST 30 INCHES WIDE & SLOPE ¼" PER FOOT AWAY FROM POOL, PROPERTY LINES & HOUSE FOOTINGS. 4' WIDE FOR PUBLIC POOLS & MUST COMPLY WITH SECTION 500(F) OF THE "2006 SOUTHERN NEVADA POOL CODE"	TWO (2) MAIN DRAINS WITH A MINIMUM THREE(3) FOOT SEPARATION, OR ONE (1) MAIN DRAIN AND ONE (1) SKIMMER ARE REQUIRED TO BE ON THE SAME SUCTION LINE INSTALLATIONS PER 2006 SOUTHERN NEVADA POOL CODE SECTION 400(H).
CONTRACTOR OR OWNER RESPONSIBLE TO VERIFY PROPERTY LINES BEFORE EXCAVATION.	PROVIDE MEANS TO DRAIN POOL TO PUBLIC SEWER PER CITY ORDINANCE
DRAINAGE AWAY FROM BUILDING AND DRAINAGE OF LOT MUST COMPLY WITH SECTIONS 1803.3, 1805.3.4., AND 3303.5 OF THE 2006 IBC. DECK-O-DRAINS MUST BE A MINIMUM OF 24" (INCHES) FROM THE FOUNDATION OF ANY MAIN STRUCTURE.	APPROVAL OF THIS PLAN DOES NOT ALLOW THE DESIGN PROFESSIONAL NOR THE CONTRACTOR TO VIOLATE THE EQUIPMENT CLEARANCE REQUIREMENTS AS PER THE MANUFACTURER'S INSTALLATION INSTRUCTIONS.
IN "TAN" and "PURPLE" SOIL AREAS, IT IS THE <u>CONTRACTOR'S</u> RESPONSIBILITY TO VERIFY THAT SULFATES ARE <u>NOT</u> PRESENT.	

**POOL EQUIPMENT SHALL NOT BLOCK THE ONLY ACCESS TO MECHANICAL EQUIPMENT.
A MINIMUM 24" PATH IS REQUIRED.**

TWO OR MORE PUMPS/MOTORS REQUIRE LOAD CALCULATIONS.

TO ALL POOL CONTRACTORS

As required by "THE NEVADA BLUE BOOK" and the "NEVADA REVISED STATUTES," all plans must be signed by the contractor for all portions that they have designed and are responsible for. The stamp and signature of the Nevada registered structural engineer is only for that structural portion of the plans that pertain to the engineer, unless the structural engineer signs for all portions.

Per "The 2004 NEVADA BLUE BOOK", page 20, section 7:

"For plans provided by a contractor: List contractor's name, license number, and name of person who prepared plans in a prominent location on the front sheet of each set of plans. This information shall be accompanied by the original signature of the contractor. In the case of electrical or plumbing work, the signature must be that of the Master or Qualified Employee." Plans shall be kept on site in a weatherproof tube or envelope. Post the "Permission to Enter" sign for all inspections.

ALL COOL DECK MUST MAINTAIN A MINIMUM OF 2" CLEARANCE TO WEEP SCREED
Per 2006 International Building Code (IBC) section 2512.1.2